

Swinging Fire Door Closers

COMPANY

OUBAO SECURITY TECHNOLOGY CO LTD

NO 809 BIXING ST
BIHU INDUSTRIAL PARK
LIANDU DISTRICT
LISHUI, Zhejiang 323006 China

R15839

Additionally Investigated to Standard UL 10C.

For self-closing doors, surface-mounted type Model(s) 203, 3234BC, 3303, 500, 501, 5014BC, 5016BC, 502, 503, 5036BC, 503BC, 504, 504BC, 505, 505BC, 514, 520, 523, 530, 534BC, 542, 542BC, 543, 543BC, 601, 602, 603, 604, 605, 632, 643, 654, 701, 7016, 702, 703, 703BC, 704, 704BC, 705, 705BC, 734BC, 9016, OB03, OB03a

For self-closing doors, without hold-open feature, concealed mounted type, size 2 Model(s) 103

Note - Above devices have been evaluated in accordance with Standard UL 10C designed to be used with swinging type fire doors rated up to and including 3 hours.



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."